CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2500249

Wall type fan

Type designation:	K7, S7, Ariakt Flex, Pro7, SmartFan X9, MEI-i7, Reton Seven, Brisa
Certificate holder:	Volution Sweden AB Smedjegatan 10 352 46 Växjö SWEDEN
The product complies with the standard(s):	EN 60335-1:2012+A11+A13+A1+A14+A2+A15+A16 EN 60335-2-80:2003+A1+A2 EN 62233:2008
Date of expiry:	19 March, 2030
EU Directive information:	The product listed has been evaluated by a Third Party Body and deemed to meet the listed standard(s). This Certificate can be used in support of a claim in meeting relevant EU legislation and mandatory Conformity Marking. And in accordance with EU law, the claim is the sole obligation of the Manufacturer/ Importer.

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed: **Date:** 19 March, 2025

Anneli Averland Johansson

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. This certificate is not issued under accreditation, by a non-approved body.

APPENDIX:

Reference No. SE-S-2500249

Technical Data:

Type designation	K7, S7, Ariakt Flex, Pro7, SmartFan X9, MEI-i7, Reton Seven, Brisa
Rated voltage (V)	230
Rated power (W)	3
Frequency (Hz)	50
Class	II
IP-Class	44
Trademark	Klimatfabriken, DUKA Ventilation, Ventaria, Flexit, getAir GmbH, National Ventilation, Reton, Pax
Test Report	2407063STO-001
Product information	-

Manufacturing Sites: Volution Sweden AB
Kattkärrsvägen 4
SE-648 31 Hälleforsnäs
SWEDEN

The instruction for use shall be written in a language acceptable according to the national regulation in the country where the product is to be used.

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed: **Date:** 19 March, 2025

Anneli Averland Johansson

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. This certificate is not issued under accreditation, by a non-approved body.